

NIDM/Admn/Maint./Renovation /2011-12
National Institute of Disaster Management
(Ministry of Home Affairs)
5B, IP Estate, Ring Road, New Delhi-110002
Telephone: 011-23702432, 23705583, 23766146

July 20, 2011

Quotation Notice

To,

Sir,

Quotations are invited on behalf of Executive Director, NIDM for the following works on or before 29.7.11 by 3.00 p.m. from the reputed firms.


| S.No. | Description | Qty | Rate |
|-------|--|--------------------------|------|
| 1 | Rewiring of light pt/fan pt/exhaust fan pt/call bell pt with 105 sq mm PVC insulated copper conductor cable in the existing surface/recessed steel conduit including dismantling earthing etc as required. | 40 | |
| 2. | Supplying and drawing of following sizes of PVC insulated copper conductor single core cable in the existing surface/recessed steel conduit/PVC casing and capping as required. a) 3 x 1.5 sqm. mm. b) 3 x 4 sqm. mm. c) 3 x 6 sqm. mm. | Item rate | |
| 3. | Re-fixing of wall fan including making connections etc. as required | Item rate | |
| 4. | Wiring for light point/fan point/exhaust fan/call bell point with 1.5 sq mm PVC insulated copper conductor cable in surface/recessed steel conduit alongwith 1 No. PVC insulated copper wire etc, as required. | Item rate | |
| 5. | Supplying and fixing of modular plate with 1 No. 20 Amps. Modular switch and 1 No. 20 Amps. 6 pin shuttered combined socket complete with connections etc as required. | 30 | |
| 6. | Re-fixing of following fittings including dismantling the old and making connection testing etc. as required (a) Spot light fitting with lamp 12 V. 50 watt. (b) down light fitting with CFL lamp 9 watt/15watt (c) 1x40 W/2 x 36 watt fluorescent fittings decorate type complete with choke starter, tubes etc. as required | 50 20 32 | |
| 7. | Wiring for sub main wiring with the following sizes of PVC insulated copper conductor single core cable in surface/recessed steel conduit as required. (a) 2x16 sq. mm. (b) 4x16 sq. mm. | 20 20 | |
| 8. | Supplying and fixing following fittings including dismantling the old and making connection testing etc. as required (a) Spot light fitting with lamp 12 V. 50 watt. (b) down light fitting with CFL lamp 9 watt/15watt (c) 1x40 W/2 x 36 watt fluorescent fittings decorate type complete with choke starter, tubes etc. as required | Approx 10 10 10 | |

Terms and condition:

1. Quotation should be free from correction and erasers.

2. Quotation received after the specified time and date will not be entertained.
3. All prices quoted must be firm and no revision in the price quoted is allowed after quotations are opened.
4. Price quoted should be inclusive of transportation charges, and all other taxes and this should be clearly specified in quotations. In the absence of any such stipulation, it will be presumed that the rates quoted are inclusive of all taxes.
5. We reserve to ourselves unfetter right to reject any or all bidders without assigning any reasons thereof

Yours truly


(Arun Sahdeo)
Consultant