

March 12, 2013

Quotation Notice

To,

Sir,

Quotations are invited on behalf of Executive Director, NIDM for the following works on or before 20.3.13 by 3.00 p.m. from the reputed firms.

S.No.	Description	Qty	Rate	Amount
1	<p>P/F/T/C of portable ABC fire Extinguishers Capacity 5kg ISI marked (Store pressure type) with ABC dry powder IS:15683 with test pressure of 30 kg/cm² and Jet length of 3 to 4 meters suitable for class A,B & C fire.</p> <p>a. The hose of the extinguisher braided with bursting pressure of not less than 50 kg/cm²</p> <p>b. The thickness of the mild steel sheet not be less than 1.60 mm thick and inner siphon tube steel sheet shall not be less than 1.00 mm thickness.</p> <p>c. Neck ring made of leaded tin bronze cap</p> <p>d. The Syphon tube of copper confirming</p> <p>All Internal surface of the body with Anti-Corrosive Treatment with thick ness of not less then 0.012 mm</p>	6 nos		
2.	<p>P/F/T/C of Carbon Dioxide type ISI marked is: 15683 fire extinguishers with mild steel body with wire braided hose ISI Marked and discharge horn made for non conductor of electricity like polyethylene, fiber glass and similar materials and fire extinguishers fulfill following technical specifications:</p> <p>a)Capacity of 4.5 kg.</p> <p>b)Extinguishing agent Liquefied gas (Co2)</p> <p>c)Gas filling ration 0.667 % per k.g.</p> <p>d)Fire rating 21B</p> <p>e)Discharge time 10-18 sec.</p> <p>f)Hose Length 1.00 Mtr.</p> <p>g)Operating temperature-30C</p> <p>h)Dimension (OD) mm-140 mm</p> <p>The above Carbon dioxide Fire Extinguisher complete in all respect to the entire satisfaction of FOCumNA</p>	5 nos		
3.	<p>P/F/T/C of portable fire extinguishers capacity 9 liters water type ISI marked IS:15683 stored pressure type</p>	4 nos		


Neuman
12/3/13

Cont: Page - 2

	and having following technical specifications: a) Capacity – 9 Ltr. b) Body material – mild steel sheet 107 to 108 mm thick c) Extinguishing agent – water d) Prepressing gas (Nitrogen) – 15 Bar e) Discharge type – Minimum 13 Sec. f) Discharge Pressure-15-19 bar g) Hydraulic test pressure – 35 bar h) Body bursting pressure – minimum 55 bar i) Hose/Nozzle – Hose minimum 400 mm j) Dimension (OD) mm – 175 mm k) Discharge throw (Metre) 2.5 mtr. l) Fire rating – 2A The complete satisfaction to the entire satisfaction of FOCumNA			
4.	Rate for buy back of the existing fire extinguisher for a) Water type (IS 940) b) CO2 type (IS2878) c) Dry Powder/ABC type (IS 13849)	6 nos 5 nos 4 nos		

Terms and condition:

1. Quotation should be free from correction and erasers.
2. Quotation received after the specified time and date will not be entertained.
3. All prices quoted must be firm and no revision in the price quoted is allowed after quotations are opened.
4. Price quoted should be inclusive of transportation charges, and all other taxes and this should be clearly specified in quotations. In the absence of any such stipulation, it will be presumed that the rates quoted are inclusive of all taxes.
5. We reserve to ourselves unfetter right to reject any or all bidders without assigning any reasons thereof
6. Time for supply of fire extinguisher is 7 days.

Yours truly,

(Ramesh Kumar)
Accounts Officer